

CONTROL MODES

- Indexer, Point-to-Point, PVT
- Camming, Gearing, Position, Velocity, Torque

COMMAND INTERFACE

- Stepper commands
Single-ended or Differential selectable
- CANopen/DeviceNet
- ASCII and discrete I/O
- $\pm 10V$ position/velocity/torque command
- PWM velocity/torque command
- Master encoder (Gearing/Camming)

COMMUNICATIONS

- CANopen/DeviceNet
- RS-232

FEEDBACK

- Digital quad A/B encoder
- Aux encoder / emulated encoder out
- Analog sin/cos encoder (-S versions)
- Digital Halls

I/O - DIGITAL

- 12 inputs, 3 outputs

DIMENSIONS: mm [in]

- 168 x 99 x 31 [6.6 x 3.9 x 1.2]



| Model | Ip | Ic | Vdc |
|------------|----|----|-----|
| R20-055-18 | 18 | 6 | 55 |
| R20-090-09 | 9 | 3 | 90 |
| R20-090-18 | 18 | 6 | 90 |
| R20-090-36 | 36 | 12 | 90 |
| R20-180-09 | 9 | 3 | 180 |
| R20-180-18 | 18 | 6 | 180 |

Add -S to part numbers above for sin/cos feedback

DESCRIPTION

Accelnet R20 is a ruggedized high-performance, DC powered drive for position, velocity (using encoder, Halls, or BEMF), and torque control of brushless and brush motors. It operates as a distributed drive using the CANopen or DeviceNet protocols, or as a stand-alone drive accepting analog or digital commands from an external motion controller. In stand-alone mode, current and velocity modes accept digital 50% PWM or PWM/polarity inputs as well as $\pm 10V$ analog. In position mode inputs can be incremental position commands from step-motor controllers, analog $\pm 10V$, or A/B quadrature commands from a master-encoder. Pulse to position ratio is programmable for electronic gearing.

Accelnet R20 models operate as Motion Control Devices under the DSP-402 protocol of the CANopen DS-301 V4.01 (EN 50325-4) application layer. DSP-402 modes supported include: Profile Position, Profile Velocity, Profile Torque, Interpolated Position Mode (PVT), and Homing. The two CAN ports are optically isolated from drive circuits.

There are twelve digital inputs eleven of which have programmable functions. These include CAN address, motion-abort, limit & home switches, stepper/encoder pulse inputs, reset, digital torque or velocity reference, and motor over-temperature. Input [IN1] is dedicated for the drive Enable. There are three programmable logic outputs for reporting an drive fault, motor brake control, or other status indications.

Drive power is transformer-isolated DC from regulated or unregulated power supplies. An AuxHV input powers control circuits for "keep-alive" operation permitting the drive power stage to be completely powered down without losing position information, or communications with the control system.

RUGGEDIZED STANDARDS CONFORMANCE

| | | |
|------------------------|---------------|---------------------------------|
| Ambient Temperature | Non-Operating | -50°C to 85°C |
| | Operating | -40°C to 70°C |
| Thermal Shock | Operating | -40°C to 70°C in 1 minute |
| Relative Humidity | Non-Operating | 95% non-condensing at 60°C |
| | Operating | 95% non-condensing at 60°C |
| Vibration | Operating | 5 Hz to 500 Hz, up to 3.85 grms |
| Altitude | Non-Operating | -400 m to 12,200 m |
| | Operating | -400 m to 5,000 m |
| Shock | Crash Safety | 75 g peak acceleration |
| | Operating | 40 g peak acceleration |
| MIL-STD specifications | MIL-STD- | 461, 704, 810, 1275, 1399 |
| IEC specifications | IEC- | 60068, 60079 |

Accelnet R20

GENERAL SPECIFICATIONS

Test conditions: Load = Wye connected load: 2 mH + 2 Ω line-line. Ambient temperature = 25°C, +HV = HV_{max}

| MODEL | R20-055-18 | R20-090-09 | R20-090-18 | R20-090-36 | R20-180-09 | R20-180-18 | |
|--------------------------------------|---|------------|------------|------------|---|-------------|---------------------------|
| OUTPUT POWER | | | | | | | |
| Peak Current | 18 (12.7) | 9 (6.4) | 18 (12.7) | 36 (25.5) | 9 (6.4) | 18 (12.7) | Adc (Arms), ±5% |
| Peak time | 1 | 1 | 1 | 1 | 1 | 1 | Sec |
| Continuous current | 6 (4.2) | 3 (2.1) | 6 (4.2) | 12 (8.5) | 3 (2.1) | 6 (4.2) | Adc (Arms) per phase |
| Peak Output Power | 0.92 | 0.79 | 1.55 | 2.95 | 1.59 | 3.15 | kW |
| Continuous " " | 0.32 | 0.27 | 0.53 | 1.06 | 0.53 | 1.06 | kW |
| Output resistance | 0.075 | 0.075 | 0.075 | 0.036 | 0.075 | 0.075 | Rout (Ω) |
| Maximum Output Voltage | Vout = HV*0.97 - Rout*Iout | | | | | | |
| INPUT POWER | | | | | | | |
| HV _{min} ~HV _{max} | +20 to +55 | +20 to +90 | +20 to +90 | +20 to +90 | +20 to +180 | +20 to +180 | Vdc, transformer-isolated |
| Ipeak | 20 | 10 | 20 | 40 | 10 | 20 | Adc (1 sec) peak |
| Icont | 6.7 | 3.3 | 6.7 | 13.3 | 3.3 | 6.7 | Adc continuous |
| Aux HV | +20 to +HV Vdc @ 500 mAdc maximum | | | | | | |
| PWM OUTPUTS | | | | | | | |
| Type | 3-phase MOSFET inverter, 15 kHz center-weighted PWM, space-vector modulation | | | | | | |
| PWM ripple frequency | 30 kHz | | | | | | |
| DIGITAL CONTROL | | | | | | | |
| Digital Control Loops | Current, velocity, position. 100% digital loop control | | | | | | |
| Sampling rate (time) | Current loop: 15 kHz (66.7 μs) Velocity, position loops: 3 kHz (333 μs) | | | | | | |
| Commutation | Sinusoidal, field-oriented control for brushless motors | | | | | | |
| Modulation | Center-weighted PWM with space-vector modulation | | | | | | |
| Bandwidths | Current loop: 2.5 kHz typical, bandwidth will vary with tuning & load inductance | | | | | | |
| HV Compensation | Changes in bus voltage do not affect bandwidth | | | | | | |
| Minimum load inductance | 200 μH line-line | | | | | | |
| COMMAND INPUTS | | | | | | | |
| CANopen communications | Profile Position, Profile Velocity, & Profile Torque, Interpolated Position (PVT), Homing | | | | | | |
| DeviceNet communications | UCMM (Unconnected Message Manager) protocol for explicit message objects <i>CANopen is the default communications mode, download firmware from web-site for DeviceNet</i> | | | | | | |
| Digital position reference | Step/Direction, CW/CCW | | | | Stepper commands (2 MHz maximum rate) | | |
| Digital torque & velocity reference | Quad A/B Encoder | | | | 2 M lines/sec, 8 M count/sec (after quadrature) | | |
| | PWM, Polarity | | | | PWM = 0~100%, Polarity = 1/0 | | |
| | PWM | | | | PWM = 50% +/-50%, no polarity signal required | | |
| | PWM frequency range | | | | 1 kHz minimum, 100 kHz maximum | | |
| | PWM minimum pulse width | | | | 220 ns | | |
| Analog torque, velocity, position | ±10 Vdc | | | | Differential, 5 kΩ impedance | | |
| DIGITAL INPUTS | | | | | | | |
| Number | 12 | | | | | | |
| Inputs [IN1~5,11,12] | 74HC14 Schmitt trigger, 330 μs RC filter, Vin-LO < 1.35 Vdc, Vin-HI >3.65 Vdc, +24 Vdc max [IN1] dedicated to drive enable function, other inputs are programmable | | | | | | |
| Input [IN6] | 74HC14 Schmitt trigger, 100 ns RC filter, Vin-LO < 1.35 Vdc, Vin-HI >3.65 Vdc, +12 Vdc max | | | | | | |
| Inputs [IN7~10] | Single-ended: Comparator with 2.5 Vdc reference, 100 ns RC filter, Vin-LO <2.3 Vdc, Vin-HI > 2.45 Vdc Differential: RS-485 line receiver on input pairs [IN9-7], and [IN10-8], 100 ns RC filters, +12 Vdc max 10 kΩ pull-up to +5 Vdc or pull-down to ground, selectable in groups, active level programmable | | | | | | |
| All inputs | | | | | | | |
| DIGITAL OUTPUTS | | | | | | | |
| Number | 3 | | | | | | |
| [OUT1], [OUT2], [OUT3] | Current-sinking MOSFET with 1 kΩ pullup to +5 Vdc through diode | | | | | | |
| Current rating | 1 Adc max, +30 Vdc max. Functions programmable External flyback diode required if driving inductive loads | | | | | | |
| MULTI-MODE ENCODER PORT | | | | | | | |
| Operation | Programmable as input for secondary (dual) digital encoder or as buffered outputs in quad A/B/X format for digital motor feedback encoder, or emulated encoder outputs from analog sin/cos motor feedback encoder (ServoTube) | | | | | | |
| Signals | Quad A/B Encoder: A, /A, B, /B, X, /X | | | | | | |
| Frequency | As input for digital encoder: 5M lines/sec, 20 M count/sec (after quadrature) As buffered outputs for digital motor encoder: 5 M lines/sec, 20 M count/sec (after quadrature) As emulated encoder outputs for sin/cos analog motor encoder: 4.5 M lines/sec, 18 M count/sec (after quadrature) | | | | | | |
| Input/output | 26C32 differential line receiver with 121 Ω line terminators, or 26C31 differential line driver | | | | | | |
| RS-232 PORT | | | | | | | |
| Signals | RxD, TxD, Gnd in 6-position, 4-contact RJ-11 style modular connector. | | | | | | |
| Mode | Full-duplex, serial communication port for drive setup and control, 9,600 to 115,200 Baud | | | | | | |
| Protocol | ASCII or Binary format | | | | | | |
| Multi-drop | ASCII interface from single RS-232 port to control multiple drives (<i>Xenus, Accelnet, Stepnet</i>) Drive with serial connection acts as master for bi-directional data flow to other drives using CAN connections in daisy-chain from drive to drive | | | | | | |
| CAN PORT | | | | | | | |
| Signals | CANH, CANL, Gnd in dual 8-position RJ-45 style modular connectors, wired as per CAN Cia DR-303-1, V1.1 CAN interface circuit and +5 Vdc supply are optically isolated from drive circuits | | | | | | |
| Format | CAN V2.0b physical layer for high-speed connections compliant | | | | | | |
| Data | CANopen Device Profile DSP-402 | | | | | | |
| Address selection | 16 position rotary switch on front panel with 3 additional address bits available as digital inputs or programmable to flash memory | | | | | | |

Accelnet R20

FEEDBACK

DIGITAL QUAD A/B ENCODER

| | |
|-----------|---|
| Type | Quadrature, differential line driver outputs |
| Signals | A, /A, B, /B, (X, /X, index signals optional) |
| Frequency | 5 MHz line frequency, 20 MHz quadrature count frequency |

ANALOG ENCODER (-S OPTION)

| | |
|---------------|--|
| Type | Sin/cos, differential line driver outputs, 0.5 V _{peak-peak} (1.0 V _{peak-peak} differential) centered about 2.5 V _{dc} typical. Common-mode voltage 0.25 to 3.75 V _{dc} |
| Signals | Sin(+), sin(-), cos(+), cos(-) |
| Frequency | 230 kHz maximum line (cycle) frequency |
| Interpolation | 10 bits/cycle (1024 counts/cycle) |

DIGITAL HALLS

| | |
|-----------|---|
| Type | Digital, single-ended, 120° electrical phase difference |
| Signals | U, V, W |
| Frequency | Consult factory for speeds >10,000 RPM |

ENCODER POWER SUPPLY

| | |
|--------------|--|
| Power Supply | +5 V _{dc} @ 400 mA to power encoders & Halls |
| Protection | Current-limited to 750 mA @ 1 V _{dc} if overloaded Encoder power developed from +24 V _{dc} so position information is not lost when AC mains power is removed |

MOTOR CONNECTIONS

| | |
|----------------------|--|
| Phase U, V, W | PWM outputs to 3-phase ungrounded Wye or delta connected brushless motors, or DC brush motors |
| Hall U, V, W | Digital Hall signals, single-ended |
| Digital Encoder | Quadrature encoder signals, A, /A, B, /B, X, /X, differential (X or Index signal not required) 5 MHz maximum line frequency (20 M counts/sec) 26LS32 differential line receiver with 121 Ω terminating resistor between complementary inputs |
| Analog Encoder | Sin/cos, differential line driver outputs, 0.5 V _{peak-peak} (1.0 V _{peak-peak} differential) centered about 2.5 V _{dc} typical. Common-mode voltage 0.25 to 3.75 V _{dc} |
| Signals | Sin(+), sin(-), cos(+), cos(-) |
| Frequency | 230 kHz maximum line (cycle) frequency |
| Interpolation | Programmable: 10 bits/cycle (1024 counts/cycle) |
| Hall & encoder power | +5 V _{dc} ±2% @ 250 mAdc max, current limited to 750 mAdc @ +1 V _{dc} if output overloaded |
| Motemp [IN5] | Motor overtemperature sensor input. Active level programmable Programmable to disable drive when motor over-temperature condition occurs Same input circuit as GP digital inputs (Digital Inputs above) |
| Brake | [OUT1,2,3] programmable for motor brake function, external flyback diode required |

STATUS INDICATORS

| | |
|------------|--|
| Amp Status | Bicolor LED, drive status indicated by color, and blinking or non-blinking condition |
| CAN Status | Bicolor LED, status of CAN bus indicated by color and blink codes to CAN Indicator Specification 303-3 |

PROTECTIONS

| | | |
|-----------------------------------|--|---|
| HV Overvoltage | +HV > HV _{max} | Drive outputs turn off until +HV < HV _{max} (See Input Power for HV _{max}) |
| HV Undervoltage | +HV < +20 V _{dc} | Drive outputs turn off until +HV > +20 V _{dc} |
| Drive over temperature | Heat plate > 80°C ±3 °C | Drive outputs turn off |
| Short circuits | Output to output, output to ground, internal PWM bridge faults | |
| I ² T Current limiting | Programmable: continuous current, peak current, peak time | |
| Motor over temperature | Digital inputs programmable to detect motor temperature switch | |

MECHANICAL & ENVIRONMENTAL


| | |
|---------------------|--|
| Size | 6.58 in (167 mm) X 3.89 in (98.8 mm) X 1.17 in (29.7 mm) |
| Weight | 0.94 lb (0.43 kg) |
| Ambient temperature | -40°C to +70°C operating, -50°C to +85°C storage |
| Humidity | 0 to 95%, non-condensing |
| Contaminants | Pollution degree 2 |
| Environment | IEC68-2: 1990 |
| Cooling | Heat sink and/or forced air cooling required for continuous power output |

Notes: 1. Digital input & output functions are programmable.

DIMENSIONS

NOTES

1. Dimensions shown in inches [mm].



Weights:
 Drive: 0.94 lb (0.43 kg)
 Heatsink: 1.0 lb (0.45 kg)

COMMUNICATIONS


CME 2 SOFTWARE

Drive setup is fast and easy using CME 2 software communicating via RS-232 or over the CAN bus. All of the operations needed to configure the drive are accessible through this powerful and intuitive program. Auto-phasing of brushless motor Hall sensors and phase wires eliminates "wire and try". Connections are made once and CME 2 does the rest thereafter. Encoder wire swapping to establish the direction of positive motion is eliminated.

Motor data can be saved as .ccm files. Drive data is saved as .ccx files that contain all drive settings plus motor data. This eases system management as files can be cross-referenced to drives. Once a drive configuration has been completed systems can be replicated easily with the same setup and performance. When operating as a stand-alone drive that takes command inputs from an external controller, CME 2 is used for configuration. When operated as a CAN node, CME 2 can be used for programming before and after installation in a CAN network. Accelnet can also be controlled via CME 2 while it is in place as a CAN node. During this process, drive operation as a CAN node is suspended. When adjustments are complete, CME 2 relinquishes control of the drive and returns it to the CAN node state.

RS-232 COMMUNICATION

Accelnet operates as a DTE device from a three-wire, full-duplex RS-232 port at 9,600 to 115,200 Baud. COM port settings must be "N81" (No parity, 8 data-bits, 1 stop-bit). The SER-CK Serial Cable Kit provides an adapter that connects to the COM port of a PC (a 9 position, male D-Sub connector) and accepts a modular cable with RJ-11 connectors for connection to the Accelnet RS-232 port (J6).




PC COM PORT SIGNALS

SER-CK SERIAL CABLE KIT ADAPTER CONNECTIONS

J5 SIGNALS

RS-232 "MULTI-DROP"

The RS-232 specification makes no allowance for more than two devices on a serial link. But, multiple Accelnet drives can communicate over a single RS-232 port by daisy-chaining a master drive to other drives using CAN cables. In the CAN protocol, address 0 is reserved for the CAN master and thereafter all other nodes on a CAN network must have unique, non-zero addresses. When the Accelnet CAN address is set to 0, it acts as a CAN master, converting the RS-232 data into CAN messages and passing it along to the other drives which act as CAN nodes.



ASCII COMMUNICATIONS

The Copley ASCII Interface is a set of ASCII format commands that can be used to operate and monitor Copley Controls Accelnet, Stepnet, and Xenus series amplifiers over an RS-232 serial connection. For instance, after basic amplifier configuration values have been programmed using CME 2, a control program can use the ASCII Interface to:

- Enable the amplifier in Programmed Position mode.
- Home the axis.
- Issue a series of move commands while monitoring position, velocity, and other run-time variables.

Additional information can be found in the ASCII Programmers Guide on the Copley website:

http://www.copleycontrols.com/motion/downloads/pdf/ASCII_ProgrammersGuide.pdf



CANOPEN NETWORKING

Based on the CAN V2.0b physical layer, a robust, two-wire communication bus originally designed for automotive use where low-cost and noise-immunity are essential, CANopen adds support for motion-control devices and command synchronization. The result is a highly effective combination of data-rate and low cost for multi-axis motion control systems. Device synchronization enables multiple axes to coordinate moves as if they were driven from a single control card.

CANOPEN COMMUNICATION

Accelnet uses the CAN physical layer signals CANH, CANL, and GND for connection, and CANopen protocol for communication. Before installing the drive in a CAN system, it must be assigned a CAN address. A maximum of 127 CAN nodes are allowed on a single CAN bus. The rotary switch on the front panel controls the four lower bits of the seven-bit CAN address. When the number of nodes on a bus is less than sixteen, the CAN address can be set using only the switch. For installations with sixteen or more CAN nodes on a network CME 2 can be used to configure Accelnet to use the rotary switch, or combinations of digital inputs and programmed offset in flash memory to configure the drive with a higher CAN node address.

CAN STATUS LED



Drive Fault conditions:

- Over or under-voltage
- Motor over-temperature
- Encoder +5 Vdc fault
- Short-circuits from output to output
- Short-circuits from output to ground
- Internal short circuits
- Drive over-temperature

Faults are programmable to be either transient or latching

Note: Red & green led on-times do not overlap.
LED color may be red, green, off, or flashing of either color.

DEVICENET

DeviceNet operation is a communications protocol that uses the CAN bus for the hardware layer. It is employed by Allen-Bradley PLC's and enables Accelnet drives to be controlled directly from A-B PLC's.


DRIVE STATUS LED

A single bi-color LED gives the state of the drive by changing color, and either blinking or remaining solid.

The possible color and blink combinations are:

- **Green/Solid:** Drive OK and enabled. Will run in response to reference inputs or CANopen commands.
- **Green/Slow-Blinking:** Drive OK but NOT-enabled. Will run when enabled.
- **Green/Fast-Blinking:** Positive or Negative limit switch active. Drive will only move in direction not inhibited by limit switch.
- **Red/Solid:** Transient fault condition. Drive will resume operation when fault is removed.
- **Red/Blinking:** Latching fault. Operation will not resume until drive is Reset.


Drive Status LED



COMMAND INPUTS

CANOPEN


Dual RJ-45 connectors that accept standard Ethernet cables are provided for CAN bus connectivity. Pins are wired-through so that drives can be daisy-chained and controlled with a single connection to the user's CAN interface. A CAN terminator should be placed in the last drive in the chain. The XTL-NK connector kit provides a D-Sub adapter that plugs into a CAN controller and has an RJ-45 socket that accepts the Ethernet cable.



16 CAN CONNECTIONS


ANALOG REFERENCE INPUT

A single ± 10 Vdc differential input takes inputs from controllers that use PID or similar compensators, and outputs a current command to the drive. Drive output current or velocity vs. reference input voltage is programmable.



XTL-NK CAN CONNECTOR KIT

The kit contains the XTL-CV adapter that converts the CAN interface D-Sub 9M connector to an RJ-45 Ethernet cable socket, plus a 10 ft (3 m) cable and terminator. Both connector pin-outs conform to the CiA DR-303-1 specification.



INDEXING

As an indexing drive, Xenus can be controlled from digital I/O lines or via CANopen, ASCII, or DeviceNet communications. Up to 32 sequences can be addressed with an additional priority sequence that can be launched from a single input or data-command. A sequence can consist of moves, homing, gain changes, time delays, wait-for-input, set-output, or camming, with each containing combinations of these. Additional flexibility is provided by the ability to replace program constants (i.e. move distance) with register addresses. A register is a storage location in drive RAM memory and can be changed via RS-232, CANopen, or DeviceNet communications. Using this technique a PLC can launch an index with digital I/O, and change the parameters over an ASCII link to find-tune the machine operation without changing the basic PLC program.

CAMMING

In camming mode Xenus synchronizes its motion with the encoder of an external device using cam tables that are stored in flash memory. A cam-table consists of two columns of numbers the first of which contains master encoder position values, and the second of which contains slave positions. When the cam profile is initiated position feedback from the external master encoder is compared to entries in the master column. When the master encoder position equals a value in the master column, the position in the slave column is sent to the drive's position loop. In this way, non-linear motion profiles can be executed from an encoder that tracks the position of moving machinery. Initiation of a camming move can be done with the master-encoder's index signal or from a digital input. For testing or stand-alone operation the master encoder can be internal to Xenus where it's frequency is programmable. Up to 10 cam tables can be stored in Xenus and each can have its own master encoder, trigger source and offsets.

DIGITAL REFERENCE INPUTS

Digital signals for control of current, velocity, and position can be single-ended or differential. Digital inputs [IN7-10] have high-speed input filters and are programmable for signals in several formats.

For single-ended signals, inputs [IN9] and [IN10] are used. For differential signals, inputs [IN9] & [IN10] should be positive with reference to their complements [IN7] and [IN8]. For clarity, the differential pairs are shown with the addition of +/- signs to indicate their relative polarity. In single-ended mode, inputs [IN7] and [IN8] are available as general purpose inputs.


The table below shows the various combinations of inputs and control modes for both single-ended and differential operation.

Current (torque, force) or velocity commands can be in one or two-wire format. In the one-wire format (50% PWM), a single input takes a square waveform that has a 50% duty cycle when the drive output should be zero. Thereafter, increasing the duty cycle toward 100% will command a maximum positive output, and decreasing the duty cycle toward 0% will produce a maximum negative output.


INPUTS AND FUNCTIONS

| Signal Format | Single-Ended | | Differential | | Control Mode |
|---------------|--------------|------------|----------------|-----------------|-------------------|
| | [IN9] | [IN10] | [IN9+], [IN7-] | [IN10+], [IN8-] | |
| PWM / Dir | PWM | Dir | PWM | Dir | Current, Velocity |
| PWM 50% | PWM 50% | No Connect | PWM 50% | No Connect | |
| Pulse / Dir | Pulse | Dir | Pulse | Dir | Position |
| CU / CD | CU (CW) | CD (CCW) | CU (CW) | CD (CCW) | |
| Quad A/B | B | A | B | A | |

SINGLE-ENDED INPUT CONFIGURATION



DIFFERENTIAL INPUT CONFIGURATION



DIGITAL INPUTS

Accelnet has twelve digital inputs, eleven of which have programmable functions. Input [IN1] is not programmable and is dedicated to the drive Enable function. This is done to prevent accidental programming of the input in such a way that the controller could not shut it down.

Two types of RC filters are used: GP (general purpose) and HS (high speed). Input functions such as Step/Direction, CW/CCW, Quad A/B are wired to inputs having the HS filters, and inputs with the GP filters are used for general purpose logic functions, limit switches, and the motor temperature sensor. Programmable functions of the digital inputs include:

- Positive Limit switch
- Negative Limit switch
- Home switch
- Drive Reset
- PWM current or velocity commands
- CAN address bits
- Step & Direction, or CW/CCW step motor position commands
- Quad A/B master encoder position commands
- Motor over-temperature
- Motion abort`


PULL-UP/PULL-DOWN CONTROL

In addition to the active level and function for each programmable input, the input resistors are programmable in four groups to either pull up to +5 Vdc, or down to ground. Grounded inputs with HI active levels interface to PLC's that have PNP outputs that source current from +24 Vdc sources. Inputs pulled up to +5 Vdc work with open-collector, or NPN drivers that sink current to ground. The table below shows the PU/PD groups and the inputs they control.`


| Group | Inputs |
|-------|------------|
| A | 1,2,3 |
| B | 4,5 |
| C | 6,7,8 |
| D | 9,10,11,12 |

DIGITAL INPUT CIRCUITS

24VDC MAX



24VDC MAX




* [IN5] connects to J2 for motor overtemp switch

DIGITAL OUTPUTS


Digital outputs are open-drain MOSFETs with 1 kΩ pull-up resistors to +5 Vdc. These can sink up to 1 A dc from external loads operating from power supplies to +30 Vdc. When driving inductive loads such as a motor brake, an external fly-back diode is required. The diode in the output is for driving PLC inputs that are opto-isolated and connected to +24 Vdc. The diode prevents conduction from +24 Vdc through the 1 kΩ resistor to +5 Vdc in the drive. This could turn the input on, giving a false indication of the drive output state.

These outputs are programmable to be on or off when active. Typical functions are drive fault indication or motor brake operation. Other functions are programmable.



BRAKE OUTPUT [OUT4]

This output is an open-drain MOSFET with an internal flyback diode connected to the +24 Vdc input. It can sink up to 1A from a motor brake connected to the +24 Vdc supply. The operation of the brake is programmable with CME 2. It can also be programmed as a general-purpose digital output.




MOTOR CONNECTIONS

Motor connections consist of: phases, Halls, encoder, thermal sensor, and brake. The phase connections carry the drive output currents that drive the motor to produce motion. The Hall signals are three digital signals that give absolute position feedback within an electrical commutation cycle. The encoder signals give incremental position feedback and are used for velocity and position modes, as well as sinusoidal commutation. A thermal sensor that indicates motor overtemperature is used to shut down the drive to protect the motor. A brake can provide a fail-safe way to prevent movement of the motor when the drive is shut-down or disabled.


DIGITAL ENCODERS

The input circuit for the motor encoder signals is a differential line-receiver with R-C filtering on the inputs. A 121 Ω resistor is across each input pair to terminate the signal pairs in the cable characteristic impedance. Encoders with differential outputs are required because they are less susceptible to noise that can be picked on single-ended outputs. For best results, encoder cabling should use twisted pair cable with one pair for each of the encoder outputs: A-/A, B-/B, and X-/X. Shielded twisted-pair is even better for noise rejection.




HALL SIGNALS

Hall signals are single-ended signals that provide absolute feedback within one electrical cycle of the motor. There are three of them (U, V, & W) and they may be sourced by magnetic sensors in the motor, or by encoders that have Hall tracks as part of the encoder disc. They typically operate at much lower frequencies than the motor encoder signals, and in *Accelnet* they are used for commutation-initialization after startup, and for checking the motor phasing after the drive has switched to sinusoidal commutation.




ANALOG SIN/COS ENCODER (-S MODELS)

The Sin and Cos inputs are differential with 121 Ω terminating resistors and accept 1.0 Vp-p signals in the format used by encoders with analog outputs such as Heidenhain, Stegman, and Renishaw, or with ServoTube motors. The resolution is programmable from 4 to 1024 counts/cycle.




MOTOR TEMPERATURE SENSOR

Digital input [IN5] connects to J2 for use with a motor overtemperature switch. The input should be programmed as a pull-up to +5 Vdc if the motor switch is grounded.



MOTOR PHASE CONNECTIONS


The drive output is a three-phase PWM inverter that converts the DC buss voltage (+HV) into three sinusoidal voltage waveforms that drive the motor phase-coils. Cable should be sized for the continuous current rating of the drive. Motor cabling should use twisted, shielded conductors for CE compliance, and to minimize PWM noise coupling into other circuits. The motor cable shield should connect to motor frame and the drive HV ground terminal (J1-4) for best results.



 = SHIELDED CABLES REQUIRED FOR CE COMPLIANCE

MOTOR BRAKE

Digital outputs [OUT1,2,3] can be programmed to power a motor-mounted brake. These brake the motor when they are in an unpowered state and must have power applied to release. This provides a fail-safe function that prevents motor motion if the system is in an unpowered (uncontrolled) state. Because brakes are inductive loads, an external flyback diode must be used to control the coil voltage when power is removed. The timing of the brake is programmable.




MULTI-MODE ENCODER PORT

This port consists of three differential input/output channels that take their functions from the Basic Setup of the drive. On drives with quad A/B encoder feedback, the port works as an output buffering the signals from the encoder. With resolver or sin/cos encoder versions, the feedback is converted to quad A/B signals with programmable resolution. These signals can then be fed back to an external motion controller that closes the position or velocity loops. As an input, the port can take quad A/B signals to produce a dual-loop position control system or use the signals as master-encoder feedback in camming mode. In addition, the port can take stepper command signals (CU/CD or Pulse/Direction) in differential format.


AS BUFFERED OUTPUTS FROM A DIGITAL QUADRATURE FEEDBACK ENCODER

When using a digital quadrature feedback encoder, the A/B/X signals drive the multi-mode port output buffers directly. This is useful in systems that use external controllers that also need the motor feedback encoder signals because these now come from J7, the Control connector. In addition to eliminating "Y" cabling where the motor feedback cable has to split to connect to both controller and motor, the buffered outputs reduce loading on the feedback cable that could occur if the motor encoder had to drive two differential inputs in parallel, each with it's own 121 ohm terminating resistor.



AS EMULATED QUAD A/B/X ENCODER OUTPUTS FROM AN ANALOG SIN/COS FEEDBACK ENCODER

Analog sin/cos signals are interpolated in the drive with programmable resolution. The incremental position data is then converted back into digital quadrature format which drives the multi-mode port output buffers. Some analog encoders also produce a digital index pulse which is connected directly to the port's output buffer. The result is digital quadrature A/B/X signals that can be used as feedback to an external control system.




AS A MASTER OR CAMMING ENCODER INPUT FROM A DIGITAL QUADRATURE ENCODER


When operating in position mode the multi-mode port can accept digital command signals from external encoders. These can be used to drive cam tables, or as master-encoder signals when operating in a master/slave configuration.

AS DIGITAL COMMAND INPUTS IN PULSE/DIRECTION, PULSE-UP/PULSE-DOWN, OR DIGITAL QUADRATURE ENCODER FORMAT

The multi-mode port can also be used when digital command signals are in a differential format. These are the signals that typically go to [IN9] and [IN10] when they are single-ended. But, at higher frequencies these are likely to be differential signals in which case the multi-mode port can be used.




DRIVE CONNECTIONS



CE = SHIELDED CABLES REQUIRED FOR CE COMPLIANCE

NOTES

1. The functions of input signals on J2-10, and J3-5,6,7,8,9,10,11,12,13, and 14 are programmable. Default functions are shown.
2. The function of [IN1] on J3-4 is always Drive Enable and is not programmable
3. Pins J3-20, J2-2, and J2-4 all connect to the same +5 Vdc @ 250 mAdc power source. Total current drawn from both pins cannot exceed 250 mAdc.
4. Multi-mode encoder port (J3-21~26) is shown configured for buffered-output of a digital primary motor encoder.
5. Connections for primary digital or analog encoders are both shown, but only one can be used at a time.



J6 RS-232

| PIN | SIGNAL |
|-----|---------------|
| 1 | No Connection |
| 2 | RxD |
| 3 | Signal Ground |
| 4 | Signal Ground |
| 5 | TxD |
| 6 | No Connection |

J6 CABLE CONNECTOR

RJ-11 style, male, 6 position

Cable: 6-conductor modular type


J4-J4 CAN BUS

| PIN | SIGNAL |
|-----|-------------------------|
| 1 | CAN_H |
| 2 | CAN_L |
| 3 | CAN_GND |
| 4 | No Connection |
| 5 | Reserved |
| 6 | (CAN_SHLD) ¹ |
| 7 | CAN_GND |
| 8 | (CAN_V+) ¹ |

J4, J5 CABLE CONNECTOR:

RJ-45 style, male, 8 position

Cable: 8-conductor, modular type



J3 CONTROL SIGNALS

| PIN | SIGNAL | PIN | SIGNAL | PIN | SIGNAL |
|-----|--------------|-----|------------|-----|------------------|
| 1 | Frame Gnd | 10 | [IN6] HS | 19 | Signal Gnd |
| 2 | Ref(-) | 11 | [IN7] HS | 20 | +5 Vdc (Note 1) |
| 3 | Ref(+) | 12 | [IN8] HS | 21 | Multi Encoder /X |
| 4 | [IN1] Enable | 13 | [IN9] HS | 22 | Multi Encoder X |
| 5 | [IN2] GP | 14 | [IN10] HS | 23 | Multi Encoder /B |
| 6 | [IN3] GP | 15 | Signal Gnd | 24 | Multi Encoder B |
| 7 | [IN4] GP | 16 | [OUT1] | 25 | Multi Encoder /A |
| 8 | [IN11] GP | 17 | [OUT2] | 26 | Multi Encoder A |
| 9 | [IN12] GP | 18 | [OUT3] | | |

J3 CABLE CONNECTOR:

High-Density D-Sub
26 Position, Male
#4-40 locking screws

J2 MOTOR FEEDBACK

| PIN | SIGNAL | PIN | SIGNAL | PIN | SIGNAL |
|-----|-----------------|-----|--------------|-----|------------|
| 1 | Frame Gnd | 6 | Hall V | 11 | Encoder /B |
| 2 | +5 Vdc (Note 1) | 7 | Encoder /X | 12 | Encoder B |
| 3 | Hall U | 8 | Encoder X | 13 | Encoder /A |
| 4 | +5 Vdc (Note 1) | 9 | Hall W | 14 | Encoder A |
| 5 | Signal Gnd | 10 | [IN5] Motemp | 15 | Signal Gnd |

J2 CABLE CONNECTOR:

High-Density D-Sub
15 Position, Male
#4-40 locking screws


J1: MOTOR & POWER

| PIN | SIGNAL |
|-----|---------------------|
| 1 | Motor U Output |
| 2 | Motor V Output |
| 3 | Motor W Output |
| 4 | Ground (HV, Signal) |
| 5 | +HV Input |
| 6 | Aux HV Input |

J1 CABLE CONNECTOR:


Terminal block, 6 position, 5.08 mm, black
Beau: 860506
RIA: 31249106
Weidmuller: 1526810000
PCD: ELFP06210
Weco: 121-A-111/06
Tyco: 796635-6

DRIVE CONNECTIONS



NOTES

1. The functions of input signals on J2-10, and J3-5,6,7,8,9,10,11,12,13, and 14 are programmable. Default functions are shown.
2. The function of [IN1] on J3-4 is always Drive Enable and is not programmable
3. Pins J3-20, J2-2, and J2-4 all connect to the same +5 Vdc @ 250 mAdc power source. Total current drawn from both pins cannot exceed 250 mAdc.
4. Multi-mode encoder port (J3-21~26) is shown configured for buffered-output of a digital primary motor encoder.



J6 RS-232


| PIN | SIGNAL |
|-----|---------------|
| 1 | No Connection |
| 2 | RxD |
| 3 | Signal Ground |
| 4 | Signal Ground |
| 5 | TxD |
| 6 | No Connection |

J6 CABLE CONNECTOR
RJ-11 style, male, 6 position
Cable: 6-conductor modular type

J4-J4 CAN BUS

| PIN | SIGNAL |
|-----|-------------------------|
| 1 | CAN_H |
| 2 | CAN_L |
| 3 | CAN_GND |
| 4 | No Connection |
| 5 | Reserved |
| 6 | (CAN_SHLD) ¹ |
| 7 | CAN_GND |
| 8 | (CAN_V+) ¹ |

J4, J5 CABLE CONNECTOR:
RJ-45 style, male, 8 position
Cable: 8-conductor, modular type



J3 CONTROL SIGNALS

| PIN | SIGNAL | PIN | SIGNAL | PIN | SIGNAL |
|-----|--------------|-----|------------|-----|------------------|
| 1 | Frame Gnd | 10 | [IN6] HS | 19 | Signal Gnd |
| 2 | Ref(-) | 11 | [IN7] HS | 20 | +5 Vdc (Note 1) |
| 3 | Ref(+) | 12 | [IN8] HS | 21 | Multi Encoder /X |
| 4 | [IN1] Enable | 13 | [IN9] HS | 22 | Multi Encoder X |
| 5 | [IN2] GP | 14 | [IN10] HS | 23 | Multi Encoder /B |
| 6 | [IN3] GP | 15 | Signal Gnd | 24 | Multi Encoder B |
| 7 | [IN4] GP | 16 | [OUT1] | 25 | Multi Encoder /A |
| 8 | [IN11] GP | 17 | [OUT2] | 26 | Multi Encoder A |
| 9 | [IN12] GP | 18 | [OUT3] | | |

J3 CABLE CONNECTOR:
High-Density D-Sub
26 Position, Male

J2 MOTOR FEEDBACK

| PIN | SIGNAL | PIN | SIGNAL | PIN | SIGNAL |
|-----|-----------------|-----|--------------|-----|----------------|
| 1 | Frame Gnd | 6 | Hall V | 11 | Encoder Cos(-) |
| 2 | +5 Vdc (Note 1) | 7 | Encoder /X | 12 | Encoder Cos(+) |
| 3 | Hall U | 8 | Encoder X | 13 | Encoder Sin(-) |
| 4 | +5 Vdc (Note 1) | 9 | Hall W | 14 | Encoder Sin(+) |
| 5 | Signal Gnd | 10 | [IN5] Motemp | 15 | Signal Gnd |

J2 CABLE CONNECTOR:
High-Density
D-Sub 15 Position,
Male

J1: MOTOR & POWER

| PIN | SIGNAL |
|-----|---------------------|
| 1 | Motor U Output |
| 2 | Motor V Output |
| 3 | Motor W Output |
| 4 | Ground (HV, Signal) |
| 5 | +HV Input |
| 6 | Aux HV Input |

J1 CABLE CONNECTOR:

Terminal block, 6 position, 5.08 mm, black
Beau: 860506
RIA: 31249106
Weidmuller: 1526810000
PCD: ELFP06210
Weco: 121-A-111/06
Tyco: 796635-6

GROUNDING CONSIDERATIONS

Power and control circuits in *Accelnet R20* share a common circuit-ground (Gnd on J1-4, and Signal Ground on J2-2, 10, 15, 20, and J3-2, 23). Input logic circuits are referenced to Signal Ground, as are analog Reference inputs, digital outputs, encoder and Hall signals. For this reason, drive Gnd terminals should connect to the users' common ground system so that signals between drive and controller are at the same common potential, and to minimize noise. The system ground should, in turn, connect to an earthing conductor at some point so that the whole system is referenced to "earth". The CAN ports are optically isolated from the drive circuits.

Because current flow through conductors produces voltage-drops across them, it is best to connect the drive HV Return to system earth, or circuit-common through the shortest path, and to leave the power-supply floating. In this way, the power supply (-) terminal connects to ground at the drive HV Return terminals, but the voltage drops across the cables will not appear at the drive ground, but at the power supply negative terminal where they will have less effect.


Motor phase currents are balanced, but currents can flow between the PWM outputs, and the motor cable shield. To minimize the effects of these currents on nearby circuits, the cable shield should connect to Gnd (J1-4).

The drive case does not connect to any drive circuits. Connections to the case are provided on connectors J2-1, and J3-1. Cables to these connectors should be shielded for CE compliance, and the shields should connect to these terminals. When installed, the drive case should connect to the system chassis. This maximizes the shielding effect of the case, and provides a path to ground for noise currents that may occur in the cable shields.

Signals from controller to drive are referenced to +5 Vdc, and other power supplies in user equipment. These power supplies should also connect to system ground and earth at some point so that they are at same potential as the drive circuits.

The final configuration should embody three current-carrying loops. First, the power supply currents flowing into and out of the drive at the +HV and Gnd pins on J1. Second the drive outputs driving currents into and out of the motor phases, and motor shield currents circulating between the U, V, and W outputs and Gnd. And, lastly, logic and signal currents connected to the drive control inputs and outputs.

For CE compliance and operator safety, the drive should be earthed by using external tooth lockwashers under the mounting screws. These will make contact with the aluminum chassis through the anodized finish to connect the chassis to the equipment frame ground.




CE = SHIELDED CABLES REQUIRED FOR CE COMPLIANCE

POWER SUPPLIES

Accelnet R20 operates typically from transformer-isolated, unregulated DC power supplies. These should be sized such that the maximum output voltage under high-line and no-load conditions does not exceed the drives maximum voltage rating. Power supply rating depends on the power delivered to the load by the drive. In many cases, the continuous power output of the drive is considerably higher than the actual power required by an incremental motion application.

Operation from regulated switching power supplies is possible if a diode is placed between the power supply and drive to prevent regenerative energy from reaching the output of the supply. If this is done, there must be external capacitance between the diode and drive.



AUXILIARY HV POWER

Accelnet R20 has an input for AUX- HV. This is a voltage that can keep the drive communications and feedback circuits active when the PWM output stage has been disabled by removing the main +HV supply. This can occur during EMO (Emergency Off) conditions where the +HV supply must be removed from the drive and powered-down to ensure operator safety. The AUX HV input operates from any DC voltage that is within the operating voltage range of the drive and powers the DC/DC converter that supplies operating voltages to the drive DSP and control circuits.


When the drive +HV voltage is greater than the AUX-HV voltage it will power the DC/DC converter. Under these conditions the AUX-HV input will draw no current.

MOUNTING & COOLING

Accelnet R20 has slots for mounting to panels at 0° or 90°. Cooling is by conduction from drive heatplate to mounting surface, or by convection to ambient.

A heatsink (optional) is required for the drive to deliver the rated continuous output current. Depending on the drive mounting and cooling means this may not be required.

CANOPEN CONFIGURATION



Multiple drives are connected as nodes on a CAN bus

Individual drives are configured using an RS-232 connection and CME 2™ software

Notes:

1. Only one SER-CK is needed per installation
2. Included in CANopen Network Kit R20-NK
3. Order one cable (1 or 10 ft) for each additional drive

+HV


POWER SUPPLY
Mains-isolated DC
Required for all systems
User-supplied

R20-HK

HEATSINK
(Optional)

| PART NUMBER | DESCRIPTION |
|-------------|--|
| R20-055-18 | Accelnet R20 Servo drive, 55 Vdc, 6/18 A |
| R20-090-09 | Accelnet R20 Servo drive, 90 Vdc 3/9 A |
| R20-090-18 | Accelnet R20 Servo drive, 90 Vdc, 6/18 A |
| R20-090-36 | Accelnet R20 Servo drive, 90 Vdc, 12/36 A |
| R20-180-09 | Accelnet R20 Servo drive, 180 Vdc, 3/9 A |
| R20-180-18 | Accelnet R20 Servo drive, 180 Vdc, 6/18 A |
| R20-CK | Connector Kit for Accelnet R20 (P1 plug, and plugs with soldercups & backshells for P2 & P3) |
| R20-NK | CAN Network Kit (Sub-D 9F to RJ-45 adapter, 10 ft. modular cable, and CAN terminator) |
| R20-NC-10 | CAN network cable, 10 ft (3 m) |
| R20-NC-01 | CAN network cable, 1 ft (0.3 m) |
| CME 2 | CD with CME 2 Configuration Software |
| SER-CK | RS-232 Cable Kit |
| R20-HK | Heatsink (optional) |

STAND-ALONE CONFIGURATION



Current or Velocity Mode Signals:
PWM & Polarity
PWM 50%
±10V Analog

Position-mode Signals:
Step/Direction
CW/CCW
±10V Analog

Electronic Gearing Signals:
A/B Quadrature encoder

CME 2™ is used for setup and configuration.

+HV

POWER SUPPLY
Mains-isolated DC
Required for all systems
User-supplied

R20-HK

HEATSINK
(Optional)

| PART NUMBER | DESCRIPTION |
|-------------|--|
| R20-055-18 | Accelnet R20 Servo drive, 55 Vdc, 6/18 A |
| R20-090-09 | Accelnet R20 Servo drive, 90 Vdc 3/9 A |
| R20-090-18 | Accelnet R20 Servo drive, 90 Vdc, 6/18 A |
| R20-090-36 | Accelnet R20 Servo drive, 90 Vdc, 12/36 A |
| R20-180-09 | Accelnet R20 Servo drive, 180 Vdc, 3/9 A |
| R20-180-18 | Accelnet R20 Servo drive, 180 Vdc, 6/18 A |
| R20-CK | Connector Kit for Accelnet R20 (P1 plug, and plugs with soldercups & backshells for P2 & P3) |
| CME 2 | CD with CME 2 Configuration Software |
| SER-CK | RS-232 Cable Kit |
| R20-HK | Heatsink (optional) |


POWER DISSIPATION

The charts on this page show the drive internal power dissipation for the *Accelnet R20* models under differing power supply and output current conditions. Drive output current is calculated from the motion profile, motor, and load conditions. The values on the chart represent the RMS (root-mean-square) current that the drive would provide during operation. The +HV values are for the average DC voltage of the drive power supply.


When +HV and drive output current are known, the drive power dissipation can be found from the chart. Once this is done use the data on the facing page to find drive thermal resistance. From this calculate the maximum ambient operating temperature. If this result is lower than the known maximum ambient temperature then a mounting with a lower thermal resistance must be used.

When the drive is disabled the power dissipation is shown on the chart as "Off". Note that this is a different value than that of an drive that is "On" but outputting 0 A current.

55 & 90 VDC MODELS



180 VDC MODELS



Accelnet R20

RoHS

MOUNTING


Thermal data for convection-cooling with a heatsink assumes a vertical mounting of the drive on a thermally conducting surface. Heatsink fins run parallel to the long axis of the drive. When fan-cooling is used vertical mounting is not necessary to guarantee thermal performance of the heatsink.

THERMAL RESISTANCE


Thermal resistance is a measure of the temperature rise of the drive heatplate due to power dissipation in the drive. It is expressed in units of °C/W where the degrees are the temperature rise *above ambient*.

E.g., an drive dissipating 16 W mounted with no heatsink or fan would see a temperature rise of 46 °C above ambient based on the thermal resistance of 2.9 °C/W. Using the drive maximum heatplate temperature of 70 °C and subtracting 46 °C from that would give 24 °C as the maximum ambient temperature the drive in which the amplifier could operate before going into thermal shutdown. To operate at higher ambient temperatures a heatsink or forced-air would be required.


TOP VIEW
VERTICAL MOUNTING
WITH FAN




END VIEWS
VERTICAL MOUNTING



| NO HEATSINK, NO FAN | °C/W |
|---------------------|------|
| CONVECTION | 2.9 |



| HEATSINK, NO FAN | °C/W |
|------------------|------|
| CONVECTION | 1.7 |



| HEATSINK + FAN | °C/W |
|---------------------|------|
| FORCED-AIR, 300 LFM | 0.6 |

MASTER ORDERING GUIDE

| PART NUMBER | DESCRIPTION |
|-------------|---|
| R20-055-18 | Accelnet R20 R20 Servo drive, 55 Vdc, 6/18 A |
| R20-090-09 | Accelnet R20 R20 Servo drive, 90 Vdc 3/9 A |
| R20-090-18 | Accelnet R20 R20 Servo drive, 90 Vdc, 6/18 A |
| R20-090-36 | Accelnet R20 R20 Servo drive, 90 Vdc, 12/36 A |
| R20-180-09 | Accelnet R20 Servo drive, 180 Vdc, 3/9 A |
| R20-180-18 | Accelnet R20 Servo drive, 180 Vdc, 6/18 A |

Add -S to part numbers above for sin/cos feedback (*ServoTube* motors)

| | QTY | DESCRIPTION |
|----------------------------------|-----|---|
| CONNECTOR KIT R20-CK | 4 | Connector, 6 Terminal, 5.08 mm |
| | 1 | 26 Pin Connector, High Density, D-Sub, Solder Cup |
| | 1 | 26 Pin Connector Backshell |
| | 1 | 15 Pin Connector, High Density, D-Sub, Solder Cup |
| | 1 | 15 Pin Connector Backshell |
| CANOPEN NETWORK KIT R20-NK | 1 | Adapter Assy, DB9 Female to RJ45 Jack (XTL-CV) |
| | 1 | CANopen Network Cable, 10 ft. (XTL-NC-10) |
| | 1 | CANopen Network Terminator (XTL-NT) |
| HEATSINK KIT R20-HK | 1 | Heatsink, Low Profile |
| | 1 | Heatsink Thermal Material |
| | 4 | Heatsink Hardware |
| R20-CV | | Adapter Assembly, DB9 Female to RJ45 Jack |
| R20-NC-10 | | CANopen Network Cable, 10 ft |
| R20-NC-01 | | CANopen network cable, 1 ft |
| R20-NT | | CANopen Network Terminator |
| CME 2 | | CME 2 Drive Configuration Software on CD-ROM |
| SER-CK | | Serial Cable Kit |

ORDERING EXAMPLE

Example: Order an R20-090-18-S servo drive with heatsink installed at factory and associated components:

| Qty | Item | Remarks |
|-----|----------------|--------------------------|
| 1 | R20-090-18-S-H | Accelnet R20 servo drive |
| 1 | R20-CK | Connector Kit |
| 1 | SER-CK | Serial Cable Kit |
| 1 | CME2 | CME 2™ CD |

Download firmware from the web-site for DeviceNet operation

<http://www.copleycontrols.com/motion/downloads/zip/DeviceNet.zip>